

DOMESTIC HOT WATER
NORTH WING UNIVERSITY HOSPITAL

8308F	8D TOILET RM.
8308G	8D CLEAN UTILITYRM.
8210	8A MED RM.
8209	8B MED. RM.
8208	PHARMACY SINK
8208	CAPPED IN CEILING
8206	8D DIRTY UTILITY RM.
8205	8B PANTRY
8203	8B STAFF TOILET
7319	HALL SINK
7208	7A MED. RM.
7206	7A DIRTY UTILITY RM.
7205	7B STAFF TOILET
6212A	CAPPED IN CHASE
6211A	CAPPED IN CHASE
6210	PHARMACY SINK
6208	CAPPED IN CHASE
6207	6B STAFF TOILET
6206	6A DIRTY UTILITY RM.
6205	6B PANTRY
6204	6A STAFF TOILET
5343	5A HALLWAY SINK NORTH
5210	5A MED. RM.
5209	5B MED. RM
5206	5A DIRTY UTILITY RM.
5205	5B PANTRY
5204	5A CLEAN UTLITY RM.
5203	5B STAFF TOILET
4217	MED RM. SENSOR SINK
4216	4A STAFF TOILET
4215	4B STAFF TOILET
4214	4A CLEAN UTILITY RM.
4213	SENSOR SINK
4212	4A DIRTY UTILITY RM.
4210	4A SHOWER
4208	4B STAFF BREAK RM.
3203A	JANITOR CLOSET
2227	MED RM.
2205	2N DIRTY UTILITY RM.

DHW119 IN RM. 7143 (HALL) OVER
ENTRANCE TO 7110 IN THE CEILING
DHW102 IN RM. 7319 (HALL) IN THE
CEILING BETWEEN RMS. 7318 & 7320
DHW104 IN RM. 7143 (HALL) IN THE
CEILING OVER ENTRANCE TO RM. 7316
DHW105 IN RM. 7143 (HALL) IN THE
'CEILING BETWEEN RMS. 7316 & 7314
DHW74 IN RM. 108 CEILING IN THE
NORTH EAST CORNER ACCESS PANEL

**NOTE: DHW342 IN RM. 1204 SOUTH
WEST CORNER ABOVE DUCT CAN BE
USED INSTEAD OF DHW74 ABOVE**

**NOTE: DHW428 IN RM. 2205 ceiling
can be used instead of dhw342 or dhw74
shutdown is the sameexcept does not
shutdown 2227 and 2205**

HW 407

CW 523